



# Certificate of Compliance

Certificate: 1962158 (LR 91712-12)

Master Contract: 156625

Project: 2191005

Date Issued: 2009/09/22

Issued to: Greyline Instruments Incorporated

16456 Sixsmith Dr.  
Long Sault, ON K0C 1P0  
Canada

Attention: Michael Blackadder

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



Issued by: Matthew Brock

Authorized Patricia Pasemko, Operations  
by: Manager

## PRODUCTS

**CLASS 2258 03** - PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non -  
Incendive Systems - For Hazardous Locations

**CLASS 2258 83** - PROCESS CONTROL EQUIPMENT-Intrinsically Safe and Non-  
Incendive - Systems-For Hazardous Locations-Certified to U.S. Standards

Class I, Groups C and D; Class II, Groups E, F and G; Class III; Type 4:

Class I, Division 2, Groups A, B, C & D

Ultrasonic Transducer, SE Series rated 10V max, 100mA max; Intrinsically safe when connected to CSA Certified Safety Barrier, rated 9.6V max and 27 ohms min. and installed per SESPEC-INST-01. Non-incendive when connected to Level and Flow meter model DFM 5.0 per Control Drawing SESPEC-INST-02.