



Certificate of Compliance

Certificate: 1536898 (LR 91712)

Master Contract: 156625

Project: 2117474

Date Issued: 2009/01/07

Issued to: Greyline Instruments Incorporated
16456 Sixsmith Dr.
Long Sault, ON K0C 1P0
Canada
Attention: Mr. Michael Blackadder

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Edward Foo, C.E.T.

Authorized by: Patricia Pasemko, Operations Manager

PRODUCTS

CLASS 2258 83 - PROCESS CONTROL EQUIPMENT-Intrinsically Safe and Non-Incendive - Systems-For Hazardous Locations-Certified to U.S. Standards

CLASS 2258 03 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non - Incendive Systems - For Hazardous Locations

Class I, Groups C and D; Class II, Groups E, F and G; Class III; Encl. 4: