

# Certificate of Compliance

Certificate: 1020388

Master Contract: 156625 (LR 91712)

Project: 1402027


Date Issued: May 21, 2003

Issued to: **Greyline Instruments Incorporated**  
16456 Sixsmith Dr.  
Long Sault, ON., K0C-1P0  
CANADA  
Attention: Mr. Philip Lauzon

*The products listed below are eligible to bear the CSA Mark shown  
with adjacent indicators 'C' and 'US'*



Issued by: Don Keel, P. Eng.

Authorized by:   
Operations Manager

## PRODUCTS

CLASS 2252 01 - PROCESS CONTROL EQUIPMENT

CLASS 2252 81 - PROCESS CONTROL EQUIPMENT - CERTIFIED TO U.S. STANDARDS

Models PSL (Pump Station Level Controller), SLT32 (Level & Flow Monitor), OCF-IV (Open Channel Flow Monitor), DFM-IV (Doppler Flow Meter), AVFM (Area-Velocity Flow Meter) rated 100-130 V ac, 50/60Hz, 0.3A; or 200-250V ac, 50/60Hz, 0.3A input; or 9-18Vdc, 0.5A input; or 18-36Vdc, 0.25A input; 4-20mA output; Relay contact 120Vrms, 5A; Enclosure Type 4X; Conduit connected; Ambient 60C.

## APPLICABLE REQUIREMENTS

CSA Std C22.2 No.	142-M1987	-	Process Control Equipment
UL Std No.	916	-	Energy Management Equipment

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognised to perform certification to U.S. Standards.