

Certificate of Compliance

Certificate: 1353498 (LR 91712-13)

Master Contract: 156625

Project: 1353498

Date Issued: August 12, 2002

Issued to: Greyline Instruments Incorporated
16456 Sixsmith Dr.
Long Sault, ON., KOC-1P0
CANADA
Attention: Mr. Philip Lauzon


*The products listed below are eligible to bear the CSA Mark shown
with adjacent indicators 'C' and 'US'*



Issued by:


T. Lu

Authorized by: Nick Alfano


Operations Manager

PRODUCTS

CLASS 2252 01 - PROCESS CONTROL EQUIPMENT, ORDINARY LOCATIONS

CLASS 2252 81 - PROCESS CONTROL EQUIPMENT - CERTIFIED TO US STANDARDS

Model LIT-25, level indicator transmitter, rated 100-130V ac, 50/60Hz, 0.5 or 200-250V ac, 0.25A, 50/60Hz or 9-18Vdc, 0.3A input; or 18-36Vdc, 0.17A input; 4-20mA output. Conduit connected. Relay contacts 250V at 1A. Ambient 60C.

Model TFT, Tank Farm Transmitter, rated and constructed as model LIT-25 except with RS-485 output.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No.	142-M1987	-	Process Control Equipment
UL Std No.	916	-	Energy Management Equipment

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.